Annual Drinking Water Quality Report Seaside Heights Water Department

For the Year 2019, Results from the Year 2018

We are pleased to present to you this year's Annual Drinking Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. This table shows the results of our monitoring for the period of January 1st to December 31st, 2018. The state allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Our drinking water source is wells. Our four wells draw groundwater from the Kirkwood-Cohansey, Piney Point and Magothy Aquifers. The New Jersey Department of Environmental Protection (NJDEP) has completed and issued the Source Water Assessment Report and Summary for this public water system, which is available at www.state.nj.us/dep/swap or by contacting NJDEP's Bureau of Safe Drinking Water at (609) 292-5550. You may also contact your public water system at 732-793-0313 to obtain information regarding your water system's Source Water Assessment. This water system's source water susceptibility ratings, and a list of potential contaminant sources is attached. We have a source water protection plan available for review at our office. The plan provides more information such as potential sources of contamination.

TEST RESULTS												
Contaminant	Level Detected	Units of Measur ement	MC LG	MCL	Likely Source of Contamination							
Radioactive Contaminants:												
Combined Radium 228 & 226 Test results Yr. 2017	N	1.5	pCi/1	0	5	Erosion of natural deposits						
Inorganic Contaminants:												
Barium Test results Yr. 2018	N	0.2	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits						
Copper Test results Yr. 2016 Result at 90 th Percentile	N	0.1 No samples exceeded the action level	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits						
Lead Test results Yr. 2016 Result at 90 th Percentile	N	ND No samples exceeded the action level	ppb	0	AL= 15	Corrosion of he erosion of natur	ousehold plumbing systems, ral deposits					
Nitrate (as Nitrogen) Test results Yr. 2018	N	0.3	ppm	10	10		rtilizer use; leaching from septic erosion of natural deposits					
Disinfection By-Products:												
TTHM Total Trihalomethanes Test results Yr. 2018	N	Range = 18 - 25 Highest detect = 25	ppb N/A		80	By-product of drinking water disinfection						
HAA5 Haloacetic Acids Test results Yr. 2018	N	Range = 4 Highest detect = 4	ppb	N/A	60	By-product of o	lrinking water disinfection					
Regulated Disinfectants	Level Detected	•	1	MRDL		MRDLG						
Chlorine Test results Yr. 2018	Average = 1.0 ppm		4	4.0 Ppm		4.0 Ppm						

We want our valued customers to be informed about their water utility. If you have any questions about this report or concerning your water utility, please contact Barbara Terregino at 732-793-0313. If you want to learn more, please attend any of our regularly scheduled Borough Council meetings at Borough Hall, 901 Boulevard. Meetings are held on the first and third Wednesdays of each month at 8:00 p.m.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams ponds, reservoirs springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases radioactive material and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in the source water include:

- * Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- * Inorganic contaminants such as: salts and metals, which can be naturally-occurring or result from urban storm-water runoff, and residential uses.
- * Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and septic systems.
- * Organic chemical contaminants, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, can come from gas stations, urban storm-water runoff, and septic systems.
- * Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

DEFINITIONS:

In the "Test Results" table you may find some terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Non-Detects (ND) - laboratory analysis indicates that the constituent is not present.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

<u>Parts per billion</u> (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Picocuries per liter (pCi/L) - picocuries per liter is a measure of the radioactivity in water.

<u>Action Level</u> - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

<u>Maximum Contaminant Level</u> - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

<u>Maximum Contaminant Level Goal</u> -The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

<u>Maximum Residual Disinfectant Level (MRDL):</u> The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

<u>Maximum Residual Disinfectant Level Goal (MRDLG)</u>: The level of a drinking water disinfectant, below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

<u>Secondary Contaminant</u> - Substances that do not have an impact on health. Secondary contaminants affect aesthetic qualities such as odor, taste or appearance. Secondary standards are recommendations, not mandates.

Recommended Upper Limit - (RUL) Recommended maximum concentration of secondary contaminants. RUL's are recommendations, not mandates.

Lead: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Seaside Heights Water Department is responsible for providing high quality drinking water, but can not control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 second to 2 minutes before using water for drinking and cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water hotline or at http://www.epa.gov/safewater/lead.

The Safe Drinking Water Act regulations allow monitoring waivers to reduce or eliminate the monitoring requirements for asbestos, volatile organic chemicals and synthetic organic chemicals. Our system received monitoring waivers for all of these types of contaminants.

To ensure the continued quality of our water, we treat it in several ways. Iron levels are decreased using lime, carbon filtration and alum. We reduce corrosion of the distribution system and household plumbing using calgon. As a precautionary measure, our water is disinfected using a sodium hypochlorite solution.

Seaside Heights Water Department- PWSID #NJ1526001

Seaside Heights Water Department is a public community water system consisting of 4 active wells.

This system's source water comes from the following aquifers: Composite Confining Unit - Kirkwood-Cohansey Water-Table Aquifer System; Potomac-Raritan-Magothy Aquifer System.

This system can purchase water from the following water systems: Lavallette Water Department, Seaside Park Water Department.

Susceptibility Ratings for Seaside Heights Water Department Sources

The table below illustrates the susceptibility ratings for the seven contaminant categories (and radon) for each source in the system. The table provides the number of wells and intakes that rated high (H), medium (M), or low (L) for each contaminant category. For susceptibility ratings of purchased water, refer to the specific water system's source water assessment report.

The seven contaminant categories are defined at the bottom of this page. DEP considered all surface water highly susceptible to pathogens, therefore all intakes received a high rating for the pathogen category. For the purpose of the Source Water Assessment Program, radionuclides are more of a concern for ground water than surface water. As a result, surface water intakes' susceptibility to radionuclides was not determined and they all received a low rating.

If a system is rated highly susceptible for a contaminant category, it does not mean a customer is or will be consuming contaminated drinking water. The rating reflects the <u>potential</u> for contamination of source water, not the existence of contamination. Public water systems are required to monitor for regulated contaminants and to install treatment if any contaminants are detected at frequencies and concentrations above allowable levels. As a result of the assessments, DEP may customize (change existing) monitoring schedules based on the susceptibility ratings.

	Pathogens			Nutrients			Pesticides			Volatile Organic Compounds			Inorganics			Radionuclides			Radon			Disinfection Byproduct Precursors		
Sources	Н	М	L	Н	М	L	Н	М	L	Н	М	L	Н	М	L	Н	М	L	Н	М	L	Н	М	L
Wells - 4			4	1	1	2			4	2		2	2		2	2	2				4		4	

Pathogens: Disease-causing organisms such as bacteria and viruses. Common sources are animal and human fecal wastes.

Nutrients: Compounds, minerals and elements that aid growth, that are both naturally occurring and man-made. Examples include nitrogen and phosphorus.

Volatile Organic Compounds: Man-made chemicals used as solvents, degreasers, and gasoline components. Examples include benzene, methyl tertiary butyl ether (MTBE), and vinyl chloride.

Pesticides: Man-made chemicals used to control pests, weeds and fungus. Common sources include land application and manufacturing centers of pesticides. Examples include herbicides such as atrazine, and insecticides such as chlordane.

Inorganics: Mineral-based compounds that are both naturally occurring and man-made. Examples include arsenic, asbestos, copper, lead, and nitrate.

Radionuclides: Radioactive substances that are both naturally occurring and man-made. Examples include radium and uranium.

Radon: Colorless, odorless, cancer-causing gas that occurs naturally in the environment. For more information go to http://www.nj.gov/dep/rpp/radon/index.htm or call (800) 648-0394.

Disinfection Byproduct Precursors: A common source is naturally occurring organic matter in surface water. Disinfection byproducts are formed when the disinfectants (usually chlorine) used to kill pathogens react with dissolved organic material (for example leaves) present in surface water.